





# The Fukushima Daiichi Incident

1. Plant Design
2. Accident Progression
3. Radiological releases
4. Spent fuel pools
5. Sources of Information


Matthias Braun  
PEPA4-G, AREVA–NP GmbH  
Matthias.Braun@AREVA.com

# The Fukushima Daiichi Incident

## 1. Plant Design

### ► Fukushima Daiichi (Plant I)

- ◆ Unit I - GE Mark I BWR (439 MW), Operating since 1971
- ◆ Unit II-IV - GE Mark I BWR (760 MW), Operating since 1974






# The Fukushima Daiichi Incident

## 1. Plant Design


### ► Building structure

- ◆ Concrete Building
- ◆ Steel-framed Service Floor



### ► Containment

- ◆ Pear-shaped Dry-Well
- ◆ Torus-shaped Wet-Well



en.wikipedia.org/wiki/Browns\_Ferry\_Nuclear\_Power\_Plant



# The Fukushima Daiichi Incident

## 1. Plant Design

### ► Service Floor






# The Fukushima Daiichi Incident


## 1. Plant Design

- Lifting the Containment closure head



# The Fukushima Daiichi Incident

## 1. Plant Design



# The Fukushima Daiichi Incident


## 2. Accident progression

### ► 11.3.2011 14:46 - Earthquake

- ◆ Magnitude 9
- ◆ Power grid in northern Japan fails.
- ◆ Reactors themselves are mainly undamaged.

### ► SCRAM

- ◆ Power generation due to fission of uranium stops
- ◆ Heat generation due to radioactive decay of fission products
  - After Scram ~6%
  - After 1 Day ~1%
  - After 5 Days ~0.5%






# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Containment Isolation
  - ◆ Closing of all non-safety related penetrations of the containment
  - ◆ Cuts off machine hall
  - ◆ If containment isolation succeeds, a large early release of fission products is highly unlikely.
- ▶ Diesel generators start
  - ◆ Emergency core cooling systems are supplied.
- ▶ Plant is in a stable save state.



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ 11.3. 15:41 Tsunami hits the plant
  - ◆ Plant Design for Tsunami height of up to 6.5m.
  - ◆ Actual Tsunami height >7m
  - ◆ Flooding of
    - Diesel generators and/or
    - Essential service water building cooling the generators
- ▶ Station Blackout
  - ◆ Common cause failure of the power supply
  - ◆ Only batteries are still available
  - ◆ Failure of all but one emergency core cooling system.



# The Fukushima Daiichi Incident

## 2. Accident progression

- ▶ Reactor Core Isolation Pump still available
  - ◆ Steam from the reactor drives a Turbine.
  - ◆ Steam gets condensed in the wet-well
  - ◆ Turbine drives a pump
  - ◆ Water from the wet-well gets pumped in reactor
  - ◆ Necessary:
    - Battery power
    - Temperature in the wet-well must be below 100°C
- ▶ As there is no heat removal from the building, the core isolation pump cannot work infinitely.






# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Reactor Isolation pump stops
  - ◆ 11.3. 16:36 in Unit 1 (Batteries depleted)
  - ◆ 14.3. 13:25 in Unit 2 (Pump failure)
  - ◆ 13.3. 2:44 in Unit 3 (Batteries depleted)
- ▶ Decay heat produces steam in reactor pressure Vessel
  - ◆ Pressure rising
- ▶ Opening the steam release valves
  - ◆ Discharge steam into the wet-well
- ▶ Descending liquid level in the reactor pressure vessel



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Reactor Isolation pump stops
  - ◆ 11.3. 16:36 in Unit 1 (Batteries depleted)
  - ◆ 14.3. 13:25 in Unit 2 (Pump failure)
  - ◆ 13.3. 2:44 in Unit 3 (Batteries depleted)
- ▶ Decay heat produces steam in reactor pressure Vessel
  - ◆ Pressure rising
- ▶ Opening the steam release valves
  - ◆ Discharge steam into the wet-well
- ▶ Descending liquid level in the reactor pressure vessel



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Reactor Isolation pump stops
  - ◆ 11.3. 16:36 in Unit 1 (Batteries depleted)
  - ◆ 14.3. 13:25 in Unit 2 (Pump failure)
  - ◆ 13.3. 2:44 in Unit 3 (Batteries depleted)
- ▶ Decay heat produces steam in reactor pressure Vessel
  - ◆ Pressure rising
- ▶ Opening the steam release valves
  - ◆ Discharge steam into the wet-well
- ▶ Descending liquid level in the reactor pressure vessel



# The Fukushima Daiichi Incident

## 2. Accident progression

- ▶ Reactor Isolation pump stops
  - ◆ 11.3. 16:36 in Unit 1 (Batteries depleted)
  - ◆ 14.3. 13:25 in Unit 2 (Pump failure)
  - ◆ 13.3. 2:44 in Unit 3 (Batteries depleted)
- ▶ Decay heat produces steam in reactor pressure Vessel
  - ◆ Pressure rising
- ▶ Opening the steam release valves
  - ◆ Discharge steam into the wet-well
- ▶ Descending liquid level in the reactor pressure vessel






# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Reactor Isolation pump stops
  - ◆ 11.3. 16:36 in Unit 1 (Batteries depleted)
  - ◆ 14.3. 13:25 in Unit 2 (Pump failure)
  - ◆ 13.3. 2:44 in Unit 3 (Batteries depleted)
- ▶ Decay heat produces steam in reactor pressure Vessel
  - ◆ Pressure rising
- ▶ Opening the steam release valves
  - ◆ Discharge steam into the wet-well
- ▶ Descending liquid level in the reactor pressure vessel



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Measured, and here referenced, liquid level is the collapsed level. The actual liquid level lies higher due to the steam bubbles in the liquid
- ▶ ~50% of the core exposed
  - ◆ Cladding temperatures rise, but still no significant core damage
- ▶ ~2/3 of the core exposed
  - ◆ Cladding temperature exceeds  $\sim 900^{\circ}\text{C}$
  - ◆ Ballooning / Breaking of the cladding
  - ◆ Release of fission products from the fuel rod gaps



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ ~3/4 of the core exposed
  - ◆ Cladding exceeds ~1200°C
  - ◆ Zirconium in the cladding starts to burn under steam atmosphere
$$\text{Zr} + 2\text{H}_2\text{O} \rightarrow \text{ZrO}_2 + 2\text{H}_2$$
  - ◆ Exothermal reaction further heats the core
  - ◆ Generation of hydrogen
    - Unit 1: 300-600kg
    - Unit 2/3: 300-1000kg
  - ◆ Hydrogen gets pushed via wet-well vacuum breakers into the dry-well



# The Fukushima Daiichi Incident

## 2. Accident progression

- ▶ at ~1800°C [Unit 1,2,3]
  - ◆ Melting of the cladding
  - ◆ Melting of the steel structures
- ▶ at ~2500°C [Block 1,2]
  - ◆ Breaking of the fuel rods
  - ◆ Debris bed inside the core
- ▶ at ~2700°C [Block 1]
  - ◆ Melting of Uranium-Zirconium eutectics
- ▶ Restoration of the water supply stops accident in all 3 Units
  - ◆ Unit 1: 12.3. 20:20 (27h w.o. water)
  - ◆ Unit 2: 14.3. 20:33 (7h w.o. water)
  - ◆ Unit 3: 13.3. 9:38 (7h w.o. water)






# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Release of fission products during melt down
  - ◆ Xenon, cesium, iodine,...
  - ◆ Uranium/plutonium remain in core
  - ◆ Fission products condense to airborne aerosols
- ▶ Discharge through valves into water of the condensation chamber
  - ◆ Pool scrubbing binds a fraction of aerosols in the water
- ▶ Xenon and remaining aerosols enter the dry-well
  - ◆ Deposition of aerosols on surfaces further decontaminates air



# The Fukushima Daiichi Incident

## 2. Accident progression


- ▶ Containment
  - ◆ Last barrier between fission products and environment
  - ◆ Wall thickness ~3cm
  - ◆ Design pressure 4-5 bar
- ▶ Actual pressure up to 8 bars
  - ◆ Normal inert gas filled (nitrogen)
  - ◆ Hydrogen from core oxidation
  - ◆ Boiling condensation chamber (like a pressure cooker)
- ▶ Depressurization of the containment
  - ◆ Unit 1: 12.3. 4:00
  - ◆ Unit 2: 13.3 00:00
  - ◆ Unit 3: 13.3. 8.41



# The Fukushima Daiichi Incident

## 2. Accident progression

- ▶ Positive and negative aspects of depressurizing the containment
  - ◆ Removes energy from the reactor building (only way left)
  - ◆ Reducing the pressure to ~4 bar
  - ◆ Release of small amounts of aerosols (Iodine, Cesium ~0.1%)
  - ◆ Release of all noble gases
  - ◆ Release of hydrogen
- ▶ Gas is released into the reactor service floor
  - ◆ Hydrogen is flammable




# The Fukushima Daiichi Incident

## 2. Accident progression

### ► Unit 1 und 3

- ◆ Hydrogen burn inside the reactor service floor
- ◆ Destruction of the steel-frame roof
- ◆ Reinforced concrete reactor building seems undamaged
- ◆ Spectacular but minor safety relevance




# The Fukushima Daiichi Incident

## 2. Accident progression

### ► Unit 2

- ◆ Hydrogen burn inside the reactor building
- ◆ Probably damage to the condensation chamber (highly contaminated water)
- ◆ Uncontrolled release of gas from the containment
- ◆ **Release of fission products**
- ◆ Temporal evacuation of the plant
- ◆ High local dose rates on the plant site due to wreckage hinder further recovery work

### ► No clear information's why Unit 2 behaved differently






# The Fukushima Daiichi Incident

## 2. Accident progression

- ▶ Current status of the Reactors
  - ◆ Core Damage in Unit 1,2, 3
  - ◆ Building damage due to various burns Unit 1-4
  - ◆ Reactor pressure vessels flooded in all Units with mobile pumps
  - ◆ At least containment in Unit 1 flooded
- ▶ Further cooling of the Reactors by releasing steam to the atmosphere
- ▶ Only small further releases of fission products can be expected



# The Fukushima Daiichi Incident

## 3. Radiological releases

### ► Directly on the plant site

#### ◆ Before Explosion in Unit Block 2

- Below 2 mSv/h
- Mainly due to released radioactive noble gases
- Measuring posts on west side. Maybe too small values measured due to wind


#### ◆ After Explosion in Unit 2 (Damage of the Containment)

- Temporal peak values 12 mSv/h
- (Origin not entirely clear)
- Local peak values on site up to 400 mSv/h (wreckage / fragments?)
- Currently stable dose on site at 5 mSv/h
- Inside the buildings a lot more

#### ◆ Limiting time of exposure of the workers necessary

# The Fukushima Daiichi Incident

## 3. Radiological releases



# The Fukushima Daiichi Incident

## 3. Radiological releases

### ► Outside the Plant site


- ◆ As reactor building mostly intact  
=> reduced release of aerosols (not Chernobyl-like)
- ◆ Fission product release in steam  
=> fast aerosol formation - large fraction deposited near the plant
- ◆ Main contribution to the radioactive dose outside plant are the radioactive noble gases
- ◆ Carried / distributed by the wind, decreasing dose with time
- ◆ No “Fall-out” of the noble gases, so no local high contamination of soil

### ► ~20 km around the plant


- ◆ Evacuations were adequate
- ◆ Measured dose up to 0.3mSv/h for short times
- ◆ Maybe destruction of crops / dairy products this year
- ◆ Probably no permanent evacuation of land necessary

# The Fukushima Daiichi Incident

## 3. Radiological releases



GRS.de




- ~50km around the plant
  - ◆ Control of Crop / Dairy products
  - ◆ Usage of Iodine pills (Caution, pills can interfere with heart medicine)



# The Fukushima Daiichi Incident

## 4. Spent fuel pools


- ▶ Spent fuel stored in pool on reactor service floor
  - ◆ Due to maintenance in Unit 4 entire core stored in fuel pool
  - ◆ Dry-out of the pools
    - Unit 4: in 10 days
    - Unit 1-3,5,6 in few weeks
  - ◆ **Leakage of the pools due to Earthquake?**
- ▶ Consequences
  - ◆ Core melt “on fresh air”
  - ◆ Nearly no retention of fission products
  - ◆ Large release



# The Fukushima Daiichi Incident

## 4. Spent fuel pools


- ▶ Spent fuel stored in pool on reactor service floor
  - ◆ Due to maintenance in Unit 4 entire core stored in fuel pool
  - ◆ Dry-out of the pools
    - Unit 4: in 10 days
    - Unit 1-3,5,6 in few weeks
  - ◆ **Leakage of the pools due to Earthquake?**
- ▶ Consequences
  - ◆ Core melt “on fresh air”
  - ◆ Nearly no retention of fission products
  - ◆ Large release



# The Fukushima Daiichi Incident

## 4. Spent fuel pools

- ▶ Spent fuel stored in pool on reactor service floor
  - ◆ Due to maintenance in Unit 4 entire core stored in fuel pool
  - ◆ Dry-out of the pools
    - Unit 4: in 10 days
    - Unit 1-3,5,6 in few weeks
  - ◆ **Leakage of the pools due to Earthquake?**
- ▶ Consequences
  - ◆ Core melt “on fresh air”
  - ◆ Nearly no retention of fission products
  - ◆ Large release
- ▶ **It is currently unclear if release from fuel pool already happened**



# The Fukushima Daiichi Incident

## 5. Sources of Information



### ► Good sources of Information

#### ◆ Gesellschaft für Reaktorsicherheit [GRS.de]

- Up to date
- Radiological measurements published
- German translation of Japanese/English web pages

#### ◆ Japan Atomic Industrial Forum [jaif.or.jp/english/]

- Current Status of the plants
- Measurement values of the reactors (pressure liquid level)

#### ◆ Tokyo Electric Power Company [Tepco.co.jp]

- Status of the recovery work
- Casualties

### ► Maybe too little information was released by TEPCO, the operator of the plant